

# WEST HANOVER TOWNSHIP WATER AND SEWER AUTHORITY



7901 Jonestown Road, Harrisburg PA 17112

Telephone 717.540.0124

<http://www.whatsa.com>

## Grinder Pump System Installation Requirements

- Myers V2 grinder pump, supplied by Authority  
<https://www.femyers.com/en/productdetails/mrg20%20single-seal%20grinder%20pump%20systems>
- Discharge connection attached to grinder pit must be connected with the stainless-steel flex line supplied with the pump.
- Connection from grinder pump pit to service lateral must be one single piece of HDPE 1.50" pipe.
- Connection from house to grinder pump pit must be 4" schedule 40 or SDR 35 pipe.
- All pipe must have minimum of 6" of 1b stone under pipe and 12" over pipe.
- All connections must be approved by the Authority and tested.
- Grinder pump pit must be anchored with concrete poured around the base as recommended by manufacturer.
- Must follow all Authority Specs for Laterals and Grinder pumps. Downloadable specs can be found on [www.whatsa.com](http://www.whatsa.com)
- Homeowner or Homeowner's contractor is responsible for all electrical work.

These specifications are subject to change based on manufacturer's recommendations. West Hanover Township Sewer Authority will not be held liable for improper installation. If you have any question please contact us directly at the number below.

### **Andrew Wetzel**

Assistant Superintendent  
West Hanover Township  
Sewer Authority  
717.540.0124